

Fire Loss is National Loss



Let us adopt Fire Safety Measures

TAMIL NADU FIRE AND RESCUE SERVICES

FIRE AND RESCUE STATION, THERVOY KANDIGAI – SIPCOT

NO OBJECTION CERTIFICATE

R.C.No.: 44/V/TVKS/2026

Date : 17.02.2026

- Ref : 1. G.O.No.122 School Education (2) Department dated 14.09.2004
2. G.O.No.123 School Education (2) Department dated 14.09.2004
3. Application received from the Principal 'Maharishi Vidya Mandir'


Certified that the MAHARISHI VIDYA MANDIR at Kavaraipettai – Sathyavedu Highway, R.V.S. Nagar, Sethilpakkam Village, Gummidipoondi Taluk, Thiruvallur District, TamilNadu – 601 201 comprised of G + 2 Floors have complied with the fire prevension and fire safety requirements in accordance with rule of State Fire Service Rules and verified by the officers concerned of Fire Officer Mr.E.Muthu inspected 16.02.2026 and that the premies is fit for occupancy for a period of THREE YEARS in accordance with rule and subject to compliance of specific conditions.

CONDITIONS

As per Tamil Nadu Fire Service Act 1985 Section 13 of Chapter II and appendix V of the Act

1. This License is valid for THREE YEARS from the date of issue.
2. Register License has to be obtained from the competent authority.
3. Fire & Life Safety Systems / Arrangements have to be provided in accordance with the requirements of NBC Part IV Fire & Life Safety 2016.
4. The First Aid Fire Fighting equipments should be maintained at all floors in accordance with the IS 2190:2010 requirements.
5. If there is any deviation from the Govt. Rules and Act the License issue will be stand cancelled.
6. Staffs should be trained in preliminary fire fighting as per GO No.713, Home (Police-17) Dated 17.08.2015 with Fire and Rescue Services Department.
7. Fire Drill should be conducted once in a six month with the local Fire & Rescue Service authorities and a permanent register should be maintained in part – II.

(Office Seal)



17/02/2026
Station Officer,

Fire & Rescue Station,
Thervoy Kandigai – Sipcot

M/s.MAHARISHI VIDYA MANDIR,
Kavaraipettai – Sathyavedu Highway,
Sethilpakkam Village,
Gummidipoondi Taluk,
Thiruvallur District.

Copy to : The District Officer, Thiruvallur.

U. VISHAL
TRUSTEE CORRESPONDENT
MAHARISHI VIDYA MANDIR
Kavarapettai Sathyavedu State Highway,
Sethilpakkam Village, Gummidipoondi Taluk,
Thiruvallur District 601 202

S.P. 15/26

PRINCIPAL
MAHARISHI VIDYA MANDIR
Kavarapettai Sathyavedu State Highway,
Sethilpakkam Village, Gummidipoondi Taluk,
Thiruvallur District 601 202